



Product Service

CERTIFICATE

No. Z2 114675 0002 Rev. 00

Holder of Certificate: **ELIN Elektrik Ins. Ms. Proje Taah.
ve San. A.S.**

mit Mah. 2535. Sok. No. 1
Cankaya
06810 Ankara
TRKIYE

Certification Mark:



Product: **Photovoltaic Module**

The product was tested on a voluntary basis and complies with the essential requirements. The certification mark shown above can be affixed on the product. It is not permitted to alter the certification mark in any way. In addition, the certification holder must not transfer the certificate to third parties. This certificate is valid until the listed date, unless it is cancelled earlier. All applicable requirements of the testing and certification regulations of TV SD Group have to be complied. For details see: www.tuvsud.com/ps-cert

Test report no.: 713205734

Valid until: 2023-12-31

Date, 2022-07-15

(Gian Maria Fontolan)



CERTIFICATE

No. Z2 114675 0002 Rev. 00

Model(s): ELNSM60M-HC-HV followed by:
-360 or -365 or -370 or -375

ELNSM72M-HC-HV followed by:
-430 or -435 or -440 or -445 or -450 or -455 or -535 or -540 or -545
or -550

ELNSM72M-HC-BF followed by:
-535 or -540 or -545 or 550

Parameters:

Construction:	Framed, with Junction Box, Cable and Connectors
Safety Class:	Class II
Maximum System Voltage:	1500Vdc
Fire Safety Class:	Class C according to UL790
Power:	from 360 W to 550 W, according model specifications
No. of Cells:	60 or 72, according model specifications
Protection degree:	IP 68

Tested according to: EN 61215-1:2016
EN 61215-2:2017
EN 61215-1-1:2017
EN 61730-1:2018
EN 61730-2:2018